MUNICIPAL CORPORATION CHANDIGARH
FIRE AND RESCUE SERVICES

FIRE SAFETY CERTIFICATE

Ref. No. CFO-FSC/2025/00166
FSC TYPE: Renewal

Date:13/03

Certified that **VEDIC GIRLS SR. SEC. SCHOOL** situated/located at **MAIN MARKET , NEAR OLD PANNA SWI MANIMAJRA** comprised of **0** (Basements), and **3** (Upper Floors) owned by Mr./Ms./M/s **VEDIC GIRLS SR SEC SCHOO** occupied by Mr./Ms./M/s **VEDIC GIRLS SR SEC SCHOOL** have complied with the Fire Prevention and Fire Safety requireme National Building Code of India and verified by the concerned Nominated Authority of Fire & Rescue Services, MC, Chandigarl the **ALL FLOORS OF SCHOOL BUILDING** of building/premises is found fit at the time of inspection in accordance with Nat Building Code of India under **EDUCATIONAL, EDUCATIONAL BUILDINGS, LESS THAN 15 METER IN HEIGHT (GROUN ONE OR MORE STOREYS)**. (Occupancy Use). This Fire Safety certificate is valid for a period of 03 years from its date of issuance u withdrawal sooner due to inadequacy/malfunctioning of Fire-fighting and Safety equipments. This Certificate is further subject to follo conditions:-

1. The installed Firefighting and Safety arrangements/equipments should be kept in working order round the clock.
2. Periodical maintenance and testing of installed Firefighting and Safety equipments/arrangements should be done and a proper record of same should be maintained and shown to the Fire Officers as and when demanded.
3. If any addition/alteration is proposed to be made in the building/occupancy use, the same should be done under intimation to the office the Chief Fire Officer, MC, Chandigarh.
4. The Owner/Occupants should have trained staff to operate the Fire Safety System provided therein.
5. Nominated Authority (Station Fire Officer) can check the arrangements of Fire Safety at any time as per norms laid down in the Fi Prevention and Safety Act as applicable to UT, Chandigarh. This certificate will be treated as withdrawn without any further notice, if an deficiency/inadequacy/non-functioning of Firefighting and Safety arrangements/ equipments is noticed by the Nominated Authority and th action as deemed fit will be initiated under the Fire Prevention and Safety Acts as applicable to UT, Chandigarh accordingly.
6. Occupants/owner should apply for renewal of Fire Safety Certificate at least three months prior to expiry of this Certificate.

Note:-

1. **This certificate must be displayed in front/near entrance of the building.**
2. **This certificate can't be used as an Ownership Proof, regularization of any violation/others, or any other purpose etc.**
3. **Holder of this certificate shall not be entitled for any sort of Compensation/Claim from the Fire and Rescue Services, MC, Chandigarh, in case of loss of life/property during any mishap.**
4. **This is a digitally signed certificate, hence no physical signature is needed.**

Digitally Signed by CFO MC Chandigarh

This Certificate will expire on 09/03/2029

Digitally signed by Inder Jeet Ranga
Date:13-03-2026 18:16:15 PM